




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2024/School/ 1151

Dated: 03/12/2024

FIRE SAFETY CERTIFICATE

Certified that the G.D. Goenka Public School Model Town (A Unit of Arya Samaj Model Town) located at Plot No. 3A, Institutional Area, Model Town, Delhi-110009 comprised of Basement, Ground & 03 upper floors owned/ occupied by G.D. Goenka Public School Model Town (A Unit of Arya Samaj Model Town). The premise was inspected by the officer concerned of this department on 19.11.2024 in the presence of Mr. Adhir Sachdeva (Director) and observed that the management has added six rooms each at first, second & third floors and all the fire prevention and fire safety arrangements as provided in the school building found in good working condition. The premise have therefore complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under class "Group B Educational" (Sr. Sec. School) with effect from03/12/2024 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ...03/12/2024 at New Delhi

(Atul Garg)
Director

Ph:-011-23414000

o/c

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. Authorized Signatory, G.D. Goenka Public School Model Town (A Unit of Arya Samaj Model Town) located at Plot No. 3A, Institutional Area, Model Town, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".